

## NOTES:

- 1. 2" TAP FOR AIR VENT SHALL BE STANDARD. THREADED TAP OR SADDLE TAP DEPENDING ON MANUFACTURER'S RECOMMENDATION FOR TYPE AND THICKNESS OF PIPE USED.
- 2. GRAVEL BEDDED MAY BE USED IN PLACE OF CONCRETE IN NON-TRAFFIC AREA AT DISCRETION OF ENGINEER.
- 3. B.I. = BLACK IRON/GALVANIZED PIPE.
- 4. MACHINE SEATING SURFACES ON BOTH COVER & FRAME.
- 5. ALL CASTING TO BE DIPPED IN ASPHALTIC PAINT AFTER MACHINING.
- 6. TOLERANCE TO BE + 125" FOR ALL DIMENSIONS.
- 7. CASTING TO BE SHOT BLASTED.
- 8. CASTING TO BE ASTM A-48 CLASS 30.

	CITY OF NORFOLK — DEPARTMENT OF UTILITIES STANDARD DETAILS	SCALE: NOT TO SCALE
DATE: 07/06	AIR VENT DETAIL	DRAWING NO.